



MA AGO Amendments to ISO-NE Energy Security Improvements Proposal

NEPOOL Markets Committee
January 14, 2020



INTRODUCTION

- The MA AGO is proposing 2 separate amendments to ISO-NE's ESI proposal at this time.
- Each is a stand alone to be voted separately.
- Each is intended to afford an opportunity to evaluate ESI or improve its value.



Proposed Amendments

Amendment #1: Eliminate RER from the ESI design.

Amendment #2: Add a look back provision to the ESI program to enable evaluation of its efficacy.



Amendment # 1: Remove RER from the ESI Design

Purpose: This amendment eliminates RER.

Method: Strike all language on RER-90 & RER-240.

Amendment may be modified or withdrawn subject to receipt of additional analysis and impact analysis runs.



Recall: ISO-NE Objectives for RER

Slide 55: July 8-10
ESI presentation

Goal #1: Ensure the next-day operating plan as produced by the day-ahead market will award sufficient 'replacement energy' options to be able to restore operating reserves consistent with NERC/NPCC restoration time standards, should a contingency occur in any hour

Goal #2: Account for load forecast *error*

~~**Goal #3:** Account for energy supply *uncertainty* from day ahead cleared energy~~

Goal #3 has been dropped from the April 2020 Filing, but may be addressed subject to FERC approval of core design (July 8-10 ESI Presentation, Slide 64)



RER should be removed from ESI design for five reasons

- **Excessive:** RER may be “baking in” a higher level of reliability than required under NERC/NPCC requirements: it is a reserve product for reserve products.
- **Process:** ISO-NE has not provided methodology for RER load forecast *error* or supply *uncertainty*.
 - Load forecast error component could result in very large option purchases; Analysis Group impact analysis does not assess quantity and cost of covering forecast error.
- **Value:** RER has no demonstrated market efficiency or reliability benefit.
- **Theory:** As designed, RER doesn’t ensure ability to recover the system.
 - There are instances where ISO could procure “enough” RER but be unable to recover the system after a large contingency.
- **Ease:** Removing RER does not disrupt other components of ESI design.



Excessive: Other ISO/RTOs see no need for RER style products

Different is not intrinsically bad, but...

- ISO-NE has not shown that it has had trouble recovering reserves historically, or that it expects to in the future.
 - No evidence that load is receiving uncompensated benefits or that RER improves extant price formation problem.
 - ISO-NE does not offer a real-time RER analogue in today's market.
- The “problems” which RER seeks to address are not included on IMM or EMM State of Market Report recommendation lists.
- No other ISO/RTO offers an RER-style product.
 - NYISO, PJM, MISO subject to same sorts of NERC or NPCC standards.
 - Some account for N-1-1 or forecast error via unpriced RAA commitments (cf. ISO-NE, Day-Ahead Enhancements; Tech Session 2, April 2, 2019).



Process: RER design remains incomplete

- “Load forecast error” isn’t defined and could be used as blank check for GWs extra RER procurement.
- ISO-NE has not provided its methodology for RER load forecast *error* or supply *uncertainty*, though it may in 1Q2020.
 - ISO-NE is “still assessing” approaches to include this uncertainty in the RER requirements (August 13-15 ESI presentation, slide 49).
 - ISO-NE presented some estimates of the magnitude of load forecast error, but has not provided its opinion on the *right* amount to procure.
- Despite being undefined, “load forecast error” is still included in ISO-NE’s September redlines (see III.1.8.5.d-e).



Value: RER has no demonstrated economic or reliability value

- ISO-NE has indicated that it will run an Impact Analysis scenario excluding RER in all hours.
 - We will return to the MC with our assessment of those results when they are presented.
- To date, Impact results imply that RER has little value.
 - All scenarios have indicated zero hours of scarcity (under both ESI and CMR).
 - This implies that RER would not be needed to avoid an energy shortage.
 - Direct costs hard to ascertain from Impact Analysis, but buying 1,200 MW of RER options will undoubtedly increase costs.
 - Impact Analysis indicates direct RER costs of \$27 to \$119 million for winter season. Some fraction is returned via RT settlement.
 - RER procurement also increases prices of other products due to cooptimization.



Theoretical Flaw: RER doesn't ensure full system recovery

- ISO-NE frames RER as a “day-ahead means to assure replacement energy” (e.g., June ESI Presentation, Slide 10).
- But, even if we buy “enough” RER in the DAM, we can *still* end up in a situation where there is insufficient energy to recover reserves after contingency.
 - ISO-NE staff agrees this outcome is possible (the following example is adapted from a conversation with Andy G.)
- Not clear that this is a *likely* outcome, but it is certainly a *possible* outcome.
 - The lack of a real-time equivalent/analogue to RER puts ISO into this position (not true with GCR: Operating Reserves or EIR: RAA).
- RER requirements may lead to *less severe* shortages than if RER set to zero, but ISO-NE hasn't demonstrated the value of any RER quantity.

Example provided in Appendix



Ease: Removing RER does not disrupt other ESI components

- RER can be removed from ESI design without hindering function of GCR and EIR (this contrasts with claims that EIR and GCR interact and moderate one another).



Conclusions Amendment # 1

- Lack of current RT RER suggests lack of need. RER offers reliability in excess of what is offered by other ISO/RTOs.
- RER has theoretical flaws which might hamper its ability to assure replacement energy after a contingency.
 - DA only product design (without RT analogue) is fundamentally flawed.
- RER design remains incomplete. ISO-NE has not specified the allowance for forecast energy error or done any work to demonstrate that that proposed quantity is just and reasonable
- RER has not demonstrated economic or reliability value in the Impact Analysis
- RER can be removed (or zeroed out) without harming other elements of the ESI design.



Amendment #2

- No later than December 2027, the EMM will report on the performance of the first three years of the ESI program.
- In its evaluation the EMM will use pre-defined performance criteria.
- ISO-NE will develop the performance criteria and will vet them through the NEPOOL stakeholder process.
- ISO will finalize the ESI evaluation criteria by December, 2021.
- Based on the recommendations of the EMM report, and with NEPOOL and IMM input, ISO-NE will develop program adjustments or explain why it believes they are unnecessary.



Amendment #2 Rationale

- ISO-NE has not defined the measures of success that will be used to evaluate the effectiveness of ESI, or any process for recalibration over time.
- ISO-NE should provide, and vet through the NEPOOL stakeholder process, criteria for evaluating the efficacy of the ESI design and assessing its impacts, both in the short and long term.
- If ESI does not meet those criteria then ISO-NE should be required to modify the design.



Conclusions Amendment # 2

- This amendment encourages a timely review of ESI's performance and a mandate to correct any deficiencies or unanticipated effects after ESI has had a reasonable amount of time to generate performance data.
- Prior agreement about performance criteria will foster fairness and transparency.



Questions?



Appendix



RER Dispatch Example Setup

Supply:

- Six units (A-F). Each unit has
 - EcoMin of 100 MW
 - EcoMax of 500 MW
 - 1 MW/min ramp rate (240 MW in 4 hour RER window).
- Monotonically increasing offers for energy & ESI options ($A < B < \dots < F$)
- Other units providing more energy and/or reserves

Demand:

- From these six units, we need:
 - 1800 MW of energy
 - 500 MW of RER options
- From other units we need more energy and ESI options (GCR, EIR)
 - Details do not matter for this example.



RER Dispatch Shortfall

1. Day Ahead Market

Clearing engine procures sufficient energy & RER

- Units A-E committed.
- Unit C is marginal in DAM.
- Unit E committed for energy at EcoMin.
- Unit F is unscheduled.

Unit Attrib.			DAM	
Unit	Emin	Emax	Energy	Options
A	100	500	500	
B	100	500	500	
C	100	500	480	20
D	100	500	220	240
E	100	500	100	240
F	100	500	0	0
Total			1800	500

2. Real-Time (Pre-Contingency)

System redispatched to reduce production costs

- Unit C increases energy by 20 MW.
- Unit E can't be backed down below its EcoMin.
- Unit D output reduced by 20 MW.

Unit Attrib.			RT (Pre Contingency)	
Unit	Emin	Emax	Energy	Ramp Potential
A	100	500	500	
B	100	500	500	
C	100	500	500	
D	100	500	200	240
E	100	500	100	240
F	100	500		
Total			1800	480

3. Real-Time (Contingency + 4 Hours)

Unit A trips, resulting in 500 MW energy loss.

- Units outside example provide TMSR/TMNSR/TMOR.
- Units B&C already at producing at EcoMax.
- Units D&E ramp up to recover reserves to extent possible.
- **System left with a 20 MW shortfall after RER deployed**

Unit Attrib.			RT (Post Contingency)	
Unit	Emin	Emax	Energy	Ramp Potential
A	100	500	0	
B	100	500	500	
C	100	500	500	
D	100	500	440	
E	100	500	340	
F	100	500	0	
Total			1780	0